

Creek County Rural Water District No. 1

139 East Buffalo Street - PO Box 406

Kellyville, OK 74039

Office 918-247-6465 Fax 918-247-6147

TTY/TDD 711

This facility is an equal opportunity employer and provider.

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER**

We routinely monitor for the presence of drinking water contaminants. Our water system recently violated drinking water standards. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what has been done to correct this situation.

Creek County Rural Water District 1 had levels of Haloacetic Acids (HAA5) above drinking water standards. Testing results we received for June 2025 show that our system exceeded the standard, or maximum contaminant level (MCL), for total Haloacetic Acids. The standard or MCL for total Haloacetic Acids is 0.060 mg/l. It is determined by averaging all the samples collected at each sampling location for the past 12 months. The level of total Haloacetic Acids averaged at our system's locations was 0.083 mg/L.

**What should I do?** There is nothing you need to do unless you have a severely compromised immune system, have an infant, or are elderly. These people may be at an increased risk and should seek advice about drinking water from their health care provider.

**What does this mean?** This is not an emergency. If it had been, you would have been notified immediately. However, some people who drink water containing Haloacetic Acids in excess of the MCL over many years may experience problems with their liver, kidneys or central nervous system and may have an increased risk of getting cancer.

What happened? What is being done? Due to the high level of rainfall in June, we experienced a higher level of organic in our source water at this time. We researched options to correct the problem. We are using enhanced treatment for the removal of the organic precursors. We have since taken samples at these locations and had them tested. Although tests show we are now in compliance, it will take several quarters before it will be reflected in the LRAA (Location Running Annual Average). We at Creek County Rural Water District 1 work around the clock to provide top quality water to every tap. Thank you for allowing us to continue providing for your family with clean quality water.

For further information, contact Mitch Conley, 918-247-6465, 139 East Buffalo St, Kellyville, OK


Please share this information with all other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in public places or distributing copies by hand or mail.

This notice is being sent to you by Creek County Rural Water District 1.

PWSID # OK 1020419

NOV # P-1020419-14-1

**Date Distributed:** 9-8-25

**Signed:**   
Mitch Conley, District Manager